



**IFB-CL-1807
Addendum #1**

Date: April 3, 2018

RFP #: IFB-CL-1807

RFP Description: Removal and Replacement of Rooftop Heating and Cooling Unit
@ Franklin Branch

Due Date: April 9, 2018 @ 2:00 p.m.

Return To: DETROIT PUBLIC LIBRARY
Purchasing Department
5201 Woodward Avenue
Detroit, MI 48202

Please see the following responses to questions submitted:

- 1.) Is this unit connected to a building automation system? If yes, we need to know what it is in order to get the proper circuit board in the unit.

We request a standard network interface with a non-java HTML 5 interface.

- 2.) Do you want a phase monitor in the unit?

There is no need for a phase monitor.

- 3.) Do you want hinged panels? The standard are panels where the tech removes screws to remove the panel.

Whatever comes standard on the unit.

- 4.) Do you want a high static blower assembly?

No, a high static blower assembly is not being requested.

5.) Do you want a power exhaust on the unit?

No

6.) Will DPL consider accepting an alternate RTU so long as it meets or exceeds the performance specifications outlined in the RFP document?

DPL will only accept any RTU that has a standard network interface with a non-java HTLM 5 interface.

All other instructions and provisions of the RFP remain unchanged.

This addendum shall be acknowledged and included with your bid response. Please be advised that failure to acknowledge this addendum may result in rejection of your bid.

Acknowledgement

Date