



INVITATION FOR BID NO. IFB-CL-1902
Addendum #2

Date: July 24, 2018

IFB #: IFB-CL-1902

Bid Name: Replacement of Steps at Skillman Branch Library

Return To: DETROIT PUBLIC LIBRARY
Purchasing Department
5201 Woodward Avenue
Detroit, MI 48202

Please note that this Invitation for Bid (IFB), due on **Thursday, August 2, 2018 by 2:00 p.m.**
Please see the following responses to questions submitted regarding this project:

1. If after footing inspection, the footing does not meet code, will the repair be a change order?
Response: If the footing does not meet code, a change order will be issued and the cost adjusted accordingly.
2. Is it possible to pour all steps as one unit and then infill with sand and pour top slab only?
Response: Each step slab is to be a separate unit.
3. Is the hand rail to be painted?
Response: The hand rail will be painted black with weather-resistant paint.
4. Clarify stamped concrete please. Is top slab to match existing?
Response: The tops step slab is to stamped or textured to match existing concrete. The other steps will be broom brushed.

All other instructions and provisions of the IFB remain unchanged.

This addendum shall be acknowledged and included with your bid response. Please be advised that failure to acknowledge this addendum may result in rejection of your bid.

Signature

Date

Printed Name