



INVITATION FOR BID NO. IFB-CL-1903
Addendum #2

Date: July 24, 2018

IFB #: IFB-CL-1903

Bid Name: Paving at Franklin Branch Library

Return To: DETROIT PUBLIC LIBRARY
Purchasing Department
5201 Woodward Avenue
Detroit, MI 48202

Please note that this Invitation for Bid (IFB), due on **Friday, August 3, 2018 by 2:00 p.m.**
Please see the following responses to questions submitted regarding this project:

1. Please provide requirements regarding the concrete?
Response: All concrete should be infused with fiber mesh.
2. Please provide clarification on the expectations for the dig out and concrete install?
Response: All grass area must be dug out 10" and 4' 21AA crush concrete base installed and 6" fiber mesh concrete installed. If current asphalt and concrete has a solid base after digging out 6", that base can be used with a 6" fiber mesh concrete installation.
3. What are the paint striping requirements?
Response: The rear parking lot shall be striped. Also, three (3) handicap parking spaces shall be striped and the handicap symbol painted on the pavement in the front, adjacent to the building.
4. Clarify requirements for the front entry door?
Response: The front entry door area paving shall have a frost footing, if one is not already there.

All other instructions and provisions of the IFB remain unchanged.

This addendum shall be acknowledged and included with your bid response. Please be advised that failure to acknowledge this addendum may result in rejection of your bid.

Signature

Date

Printed Name