



**RFP #IFB-CL-1915  
Addendum #1**

Date: December 11, 2018  
RFP #/Description: IFB-CL-1915 - Removal of Asbestos at Jefferson Branch Library  
Due Date: December 20, 2018 @ 2:00 p.m.  
Return To: DETROIT PUBLIC LIBRARY  
Purchasing Department  
5201 Woodward Avenue  
Detroit, MI 48202

Please see the following responses to the questions raised during the mandatory walk-thru at the Jefferson Branch, held on Tuesday, December 11, 2018:

1. Who is going to be responsible for the final air monitoring report?

*The successful vendor is responsible for all third party air monitoring. This price shall be included in your total bid (see IFB page #7).*

2. Which technique should be used for the removal of the glue, chemical or mechanical?

*DPL is requesting that the mechanical technique be used for removal of the glue.*

3. Will vendor remove all mastic throughout the building?

*Yes, the mastic shall be removed, per the Scope of Work.*

All other instructions and provisions of the IFB remain unchanged.

This addendum shall be acknowledged and included with your bid response. Please be advised that failure to acknowledge this addendum may result in rejection of your bid.

---

Acknowledgement

---

Date