



**IFB-CL-1926
Addendum #1**

Date: June 20, 2019

Solicitation #: IFB-CL-1926

Description: Replacement of AHU Coils at Main Library

Due Date: June 25, 2019 @ 2:00 p.m.

Return To: DETROIT PUBLIC LIBRARY
Purchasing Department
5201 Woodward Avenue
Detroit, MI 48202

Please see the attached revised requirements and price sheet for the subject bid:

All other instructions and provisions of the IFB remain unchanged.

This addendum shall be acknowledged and included with your bid response. Please be advised that failure to acknowledge this addendum may result in rejection of your bid.

Acknowledgement

Date

REVISED- GENERAL SCOPE OF WORK

The Detroit Public Library is seeking to replace leaking chill water coils located at the Main Branch, 5201 Woodward Avenue, Detroit, MI 48202, as follows:

Item #1: Water Coils –Unit E-1A:

1. Remove and install four (4) AHU's leaking chill water coils. Units E-1A is located in the sub-basement and its control isolation valve must be replaced as part of the coil replacement.
2. Replace the AHU E-1A chill water coil system including the installation of a chilled water valve Pneumatic Electric to Pneumatic transfer.
3. Install a Johnson Control's stand-alone controller controlled by supply air sensor.
4. Test and balance the AHU. If any valve deficiencies are found, repairs are to be quoted as separate line item.

Removal and Installation of Four (4) AHU Chill Water Coils (E-1A):

Quoting on: _____

Mfd. By: _____

Bid (E-1A): _____
(Numerically)

(Written)

Item #2: Water Coils – Unit E-3

1. Remove and install one (1) AHU leaking chill water coil. AHU...E-3 is located in the Print Shop and a large opening must be cut into the side of the AHU to replace the leaking chill water coil. The control valve for this AHU appears to be working that controls the water.
2. Replace the AHU E-3 chill water coil system including the installation of the Chilled water valve Pneumatic Electric to Pneumatic transfer.
3. Install a Johnson Control's stand-alone controller controlled by supply air sensor.
4. Test and balance the AHU. If any valve deficiencies are found, repairs are to be quoted as separate line item.

IFB-CL-1926
Addendum #1
Page 3 of 3

Quoting on: _____

Mfd. By: _____

Bid (E-3): _____
(Numerically)

(Written)

Should there be any discrepancies, the written total shall be the accepted amount for this bid.

*Note: The Detroit Public Library is a Government Unit and exempt from State Sales Tax.

Work hours will be Monday – Friday eight (8) hour per day with a starting time of 8:00 pm to 4:00 pm.

The Contractor will be responsible for all work, unless specifically excluded, necessary to result in a complete and fully finished project.

All work shall be in strict accord with the state of Michigan Code, as enforced by the City of Detroit.

Price

Prices shall include:

All labor and material to provide a finish product
All necessary mechanical and re connect electrical connections
Startup to include performance and warranty registration

****Prices are Firm****