



**RFP #DPL-CL-1804
Addendum #4**

Date: February 5, 2018

RFP #: DPL-CL-1804

RFP Description: Labor, Materials and Equipment Necessary to Provide Preventative Maintenance and Repairs to Heating and Cooling Equipment for One Year with an Option to Renew for Two (2) Additional One-Year Periods

Due Date: February 15, 2018 @ 2:00 p.m.

Return To: DETROIT PUBLIC LIBRARY
Purchasing Department
5201 Woodward Avenue
Detroit, MI 48202

This addendum is being issued to provide clarification to the following questions (previously answered in Addendum #3):

1. Do you want exhaust fans included in the pricing? (Question #4 – Addendum #3)

Response: Exhaust fans should be included in the pricing as a separate line item.

2. Building exhaust fans are part of PM checks? (Question #17 – Addendum #3)

Response: Exhaust fans are not part of the PM inspection. The building exhaust fans specifically located at all of the branches, excluding Main Library, are not part of the PM checks. However, the exhaust fans on the air handling units at the Main Library shall be included as a part of the PM checks.

All other instructions and provisions of the RFP remain unchanged.

This addendum shall be acknowledged and included with your bid response. Please be advised that failure to acknowledge this addendum may result in rejection of your bid.

Acknowledgement

Date